



## **Karnataka Fire & Emergency Services**

**Office of the District Fire Officer**

**Yelahanka Fire Station, Nitte Minakshi College Road,  
Vadeyarapura, Bagalur Cross, Yelahanka, Bengaluru-64**



**No. 67/DFO/YLFS/2024**

**Dated: 02-07-2024**

**To,**

**THE PRINCIPAL**

**M/s. Katherine Public School,  
No.87, Vidyanagar Cross,  
Bengaluru North-562157.**

**Sir,**

**Sub:** Issue the Renewal of "**Fire Compliance Certificate**" with respect to fire prevention, fire fighting and evacuation measures required at **M/s. Katherine Public School, Situated at No.87, Vidyanagar Cross, Bengaluru North.**

**Ref:** 1) No: 49/ DFO/YLFS/2022 Dated: 23-11-2022.

2) No: 49/ DFO/YLFS/2022 Dated: 30-11-2022.

3) Your request letter Dated: 28-07-2024.

<<<>>>

With reference to the subject cited (1) above, a conditional fire safety recommendation was issued for **M/s. Katherine Public School, Situated at No.87, Vidyanagar Cross, Bengaluru North** with a condition to fulfill all the recommendation stipulated in Fire safety Recommendation and Compliance the same within 03 months.


With reference to the subject cited (2) above, a conditional Fire Compliance Certificate was issued for **M/s. Katherine Public School, Situated at No.87, Vidyanagar Cross, Bengaluru North.**

With reference cited (3) above, the management of **M/s. Katherine Public School**, had requested for the Renewal of Compliance Certificate from our department. This School Building Comprising Lower Ground Floor, Ground Floor & 02 Upper Floors Only Situated at No.87, Vidyanagar Cross, Bengaluru North. In this regard the building was inspected by District Fire Officer, Yelahanka Fire Station on 01-07-2024 and Submitted the report & Recommended to Issue the Renewal of Compliance Certificate.




Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the Renewal of "Fire compliance Certificate" to M/s. Katherine Public School, Situated at No.87, Vidyanagar Cross, Bengaluru North. Subject to proper maintenance of fire fighting systems in good working condition and to impart training for 40% of employees/staff in basic fire fighting at R.A Mundkur Fire & Emergency Services Academy, Bangalore within 90 days from the date of issue of this report.

"This Clearance report is valid for one year from the date of issue and is renewable without fail".

  
**PRINCIPAL**  
 Katherine Public School  
 Vidyanagar P.O.  
 Bangalore North - 562157

  
 Yours faithfully  
**District Fire Officer**  
 Karnataka Fire & Emergency Services  
 Yelahanka (Jakkur) Fire Station  
 Bangalore-560 064

  
**MANAGER**  
 Katherine Public School  
 Vidyanagar P.O.  
 Bangalore North - 562157